

February 9, 2010

BIO-MICROBICS, INC.
ALLISON BLODIG
8450 COLE PKWY.
SHAWNEE KS 66227

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER *
Manufacturer: BIO-MICROBICS, INC.
Product Name: SaniTEE® Wastewater Screens
Model Number(s): SNT 818, ST 838
[FILTERS ,8 IN. DIA.; FLOW RANGE UP TO 6,000 AND 10,000 GPD, RESPECTIVELY]
Product File No: 20100078

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of JULY 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- A means of venting the gases formed inside of the tank in which this product is installed shall be provided in accordance with s. Comm 84.25 (5), of the Wisconsin Administrative Code.
- This product must be installed in accordance with the manufacturer's installation instructions and with the bottom of the product above the scum level in the tank.
- This product shall be cleaned and maintained at the same time as the tank pumping interval.

This approval supersedes the approval issued on 7/11/2007 under product file number 20070218. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070218.

*** TO ASSIST USERS IN ON-LINE SEARCHES FOR COMMERCE PLUMBING PRODUCT APPROVALS AND TO BETTER DESCRIBE THIS PART/DEVICE, AS OF THE DATE OF THIS COMMUNICATION, THIS PRODUCT TYPE DESCRIPTION HAS BEEN CHANGED FROM SEWAGE TREATMENT APPARATUS (STA) TO SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER (STAF); SEE ALSO http://commerce.wi.gov/php/sb-ppalopp/prodcode_alpha_list.php.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov